

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D Mirza Ghalib Street, Kolkata- 700 016**

Memo No : IND/WB/FES/20192020/56480

DATE: 14/07/2019

From :

**The Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

**The Office Superintendent of North Point Senior Secondary Boarding School
Gorakshabasi Mandir Complex, Arjunpur, Kolkata- 700059
Bidhan Nagar F.S., Bidhannagar (South),
North 24 Parganas - 700059 .**

Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction of a G+III storied under group Education Building in the name & style 'North Point Senior Secondary Boarding School' at the premises no. Gorakshabasi Mandir Complex, Arjunpur, Kolkata - 700 059.

This is in reference to your Application No. IND/WB/FES/20192020/56480, dated 14/07/2019, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of a G+III storied under group Education Building in the name & style 'North Point Senior Secondary Boarding School' at the premises no. Gorakshabasi Mandir Complex, Arjunpur, Kolkata - 700 059..

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. To up-keep the Fire Safety Measures of the aforesaid building the following safety measures are to be incorporated:-


Secretary
North Point Senior Secondary Boarding School
Gorakshabasi Mandir Complex
Arjunpur, Kolkata-700059
Affiliated with CBSE, Delhi


Principal
North Point Senior Secondary Boarding School
Gorakshabasi Mandir Complex
Arjunpur, Kolkata - 700 059
Affiliated with C.B.S.E

.Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.

2.The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.

3.To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.

4.Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear, particularly lines above false ceiling and ducts.

5.A Fire Control Room including a CCTV system will have to be maintained, which observe all floors of the building.

6.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the building.

7.The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and capable to operate in the event of Fire and Testing.

8.Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.

9.Transformer and switch gear room shall be protected with automatic CO2 or D.C.P. Fire Extinguishers confirming I.S. specification.

10.Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.

11.Gas sensor should be provided at Gas Bank.

12.Unauthorized cooking arrangement in any floor of the building using L.P.G., Kerosene etc. shall not be permitted and Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.

13.First-Aid Fire Fighting system shall be provided as per I.S. specification.



Secretary
North Point Senior Secondary Boarding School
Gorakshabasi Mandir Complex
Arjunpur, Kolkata-700059
Affiliated with CBSE Delhi



Principal
North Point Senior Secondary Boarding School
Gorakshabasi Mandir Complex
Arjunpur, Kolkata - 700 059
Affiliated with C.B.S.E

14. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.

15. If required the old lines shall have to be replaced with new lines and the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.

16. Existing lift shall be treated as fire lift in case of emergency.

17. Periodical flashing of water from the Hydrant and Sprinkler pipe lines shall be made to maintain the efficient working performance of above mentioned system.

18. The Fire Check Door shall be sealed with rubber sealing properly in order to prevent the percolation of smoke.

19. The Fire Safety Audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.

20. This Fire Safety Certificate is valid for 3(Three) year from the date of issue of this letter and have to be renewed within validity limit.

21. A certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, performance of all the life and fire safety arrangements and installation of the building.

Director
West Bengal Fire & Emergency Services

Validity unknown

Digitally signed by RATAN
KUMAR HALDER

Date: 2019.07.14 21:14:41 IST

Page 1 of 2


Secretary,
North Point Senior Secondary Boarding School
Gorakshabasi Mandir Complex
Arjunpur, Kolkata-700059
Affiliated with CBSE, Delhi


Principal
North Point Senior Secondary Boarding School
Gorakshabasi Mandir Complex
Arjunpur, Kolkata - 700 059
Affiliated with C.B.S.E