



सत्यमेव जयते

Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Ghoshpara Road, P.O.- Bengal Enamel, Pin :- 743122

Memo No.: FSR/211862406300002868

Date : 08-08-2024

From :
Divisional Fire Officer
North 24 Parganas Division
West Bengal Fire & Emergency Services

To :
North Point Senior Secondary Boarding School
VILL-RAJARHAT,NANGOLPOTA,KHARIBARI ROAD,P/S-BARASAT,DIST-NORTH 24 PARGANAS,KOLKATA-700135.

Sub: Fire Safety Recommendation for existing G+3 storied building under group Educational occupancy in the name & style of "North Point Senior Secondary Boarding School" at the premises of -: VILL-RAJARHAT,NANGOLPOTA,KHARIBARI ROAD,P/S-BARASAT,DIST-NORTH 24 PARGANAS,KOLKATA-700135. .

Memo No.: FSR/211862406300002868

This is in reference to your AIN 211862406300002868 dated 28-Jun-2024 regarding Fire Safety Recommendation for existing G+3 storied building under group Educational occupancy in the name & style of "North Point Senior Secondary Boarding School" at the premises of -: VILL-RAJARHAT,NANGOLPOTA,KHARIBARI ROAD,P/S-BARASAT,DIST-NORTH 24 PARGANAS,KOLKATA-700135.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing Fire Safety Recommendation in favor of the aforesaid building for compliance of the following fire safety measure.

Recommendation :

CONSTRUCTION:

1. The whole construction of the existing building shall be carried out as per approved plan drawings conforming the relevant building rules of local Municipal Body.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
3. Arrangement shall have to be made for sealing all the vertical and horizontal ducts by the materials of adequate fire resisting capacity.

OPEN SPACE AND APPROACH:



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in Unique Number : 211862406300002868

Manager

North Point Senior Secondary Boarding School
(Affiliated to C.B.S.E, New Delhi)
Nangalpota, Kharibari Road, Kolkata-700135

Principal
North Point Senior Secondary Boarding School
(Affiliated to C.B.S.E, New Delhi)
Nagolpota Kharibari Road, Kolkata-700135

1. The approach roads shall be sufficiently strong to withstand the load of Fire Engine weighing 45M.T.
2. All the Passage way should be kept clear for free access.
3. STAIRCASE :
 1. The staircase of the building shall be enclosed type. Entire construction shall be made of bricks / R.C.C. type having Fire resisting capacity not less than 4 hours.
 2. The width of the staircases shall be made as marked in the plan. Corridors and the exit doors shall conforming the relevant building rules.All the staircase shall be extended up to terrace of the building and shall be negotiable to each other without entering into any room.

FIRE FIGHTING WATER:

Underground water reservoir having water capacity of 30000 ltrs. and overhead water reservoir having capacity of 20000 ltrs. exclusively for fire-fighting purpose with replenishing arrangements @ 1000 ltrs/min. preferably from two different sources of water supply shall be provided. The water reservoirs shall have overflow arrangement with the domestic water reservoir as well as to avoid stagnancy of water. The water reservoir shall be kept full at all time.

HYDRANT SYSTEM:

1. The building shall be provided with Down Comer along with Hose Reel Hose connected to terrace tank through the terrace pump capacity of 900 LPM with providing one 100 mm. internal diameter pipe line with provision of landing valves at the ground floor level. The system shall be so designed that shall be kept charged with water all the time under pressure and one stand by pump at same capacity shall also be installed. In both cases the running pressure shall not be less than 3.5 kg/ sq.cm. All other requirements shall conform I.S. 3844-1989.
2. Provision of Hose Reel in conjunction with down comer shall be made at ground floor level conforming relevant I.S. specifications.
3. Proper replenishing arrangements shall have to be made to keep the overhead water reservoir full at all time.
4. Provision of two way collecting head for uses of Fire Service must be provided at the entrance of the building.
5. Provision of the fire pump shall have to be made to supply water at the rate designed pressure and discharge into the water based system, which shall be installed in the roof of the building, one such pump shall always be kept as stand by pump.

Sprinkler Protection IS- 15105:2002: -

The automatic sprinkler system shall be installed covering at Conference room. Alarm gong to be incorporated along with the sprinkler system.

ELECTRICAL INSTALLATION AND DISTRIBUTION:

1. The electrical installation including Transformers, Switch Gear, Main & Meters etc. and the distribution system of the premises shall be made satisfying the code of practice for Fire Safety in general building as laid down in I.S. specification.
2. The vertical and horizontal electrical ducts shall be sealed at each floor level by fire resisting materials.
3. The electrical installation shall be adequately protected with CO2/D.C.P. Fire Extinguishers conforming I.S. specification.
4. Arrangement for alternative power supply shall have to be made to supply power with the help of a generator to operate at least the Fire Pump, Deep Tube-Well Pump, Fire Alarm System etc. and also for illuminating the Staircase, Corridors, Lobbies etc. and other places of assembly of the building in case of normal power failure.

ALARM SYSTEM AND PA SYSTEM:

1. Manually operated Electrical Fire Alarm System with at least one number of break glass type call boxes fitted with Hooters along with Public Address System at each floor connecting with visual panel board shall be made in Control Room. The Control Room shall be located at entrance of ground floor of the building; other requirements of the system shall be made conforming I.S. specifications.
2. Hooters will be sounded in such a manner so that an operation of Manual Call Point. Hooters will be sounded on the same floor and immediate alternate floor.

GENERAL RECOMMENDATIONS:

1. Fire License shall have to be obtained for proposed storing and processing L.P.G. and other highly combustible articles.
2. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in Unique Number : 211862406300002868

3. Directional sign of escape route shall be displayed prominently.
4. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
5. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipments installed in the building to keep them in perfectly good working conditions at all times.
6. A crew of trained Fireman shall be maintained round the clock for safety of the building.
7. Mock Fire practice and Evacuation Drill shall be performed periodically with participation of all occupants of the building.
8. No Kitchen room shall be made inside the building it should be in separate enclosure apart from main building.
9. LPG Bank shall be constructed outside of the main building as per I.S. 6044.

On compliance of all the above Life and Fire Safety Recommendation, the Director General, West Bengal Fire & Emergency Services shall be approved for necessary inspection and testing of all the installation, Fire Safety Certificate in favour of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

N.B. : Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this Fire Safety Recommendation will be treated as

Memo No.: FSR/211862406300002868




Signature valid

Digitally Signed.
Name: SAROJ KUMAR BAG
Date: 08-Aug-2024 21:58:30
Reason: D-Sign
Location: E-Dist 2.0
Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in Unique Number : 211862406300002868


AMIT SETHI MONDAL
Manager
North Point Senior Secondary Boarding School
(Affiliated to C.B.S.E, New Delhi)
Nangalpota, Kharibari Road, Kolkata-700135


North Point Senior Secondary Boarding School
(Affiliated to C.B.S.E, New Delhi)
Nagalpota Kharibari Road, Kolkata-700135
Scanned with OKEN Scanner